

ADDENDUM No: 1

CTICC 005/2017: Mechanical, Electrical and builder's work – Installation, testing, commissioning and handing over of generators

Dear Tenderer,

Enquiry 1:

"After reading through the BOQ supplied in the tender document
Section 2 Electrical installation

- | | |
|--------------|-------|
| 1 a) 1000kva | QTY-2 |
| c) 500kva | QTY-1 |

Does this mean:

1. Do we need to supply you our own units using the specifications of Zest WEG Group?
2. Do we need to buy these units from Zest WEG Group using their specifications?"

Response 1:

In the BOQ and document we only refer to the installation of the generator sets and **not the supply**. We do not make any reference to supply as the generator sets have been supplied by Zest Weg under a separate contract and are currently being stored on site. This tender deals with the installation of these generator sets and its associated works.

Since these sets are still under guarantee by Zest Weg, we have to ensure that they are involved with both the installation and the commissioning of these units. We have therefore allowed the tenderer's to put a mark-up on any works that Zest Weg needs to be involved in under this contract.

Kind Regards;


Eben Lewis (Supply Chain Manager)

Cape Town International Convention Centre Company SOC Ltd (RF) (CTICC)